

HEIDELBERGCEMENT INDIA LTD - AMMASANDRA
 HeidelbergCementCement Group
AMMASANDRA

STACK MONITORING REPORT FOR THE MONTH OF Feb - 2015

LOCATION	S-1	S-2	S-3	S-4	S-5	S-6
Date of monitoring	13.02.2015	8.2.2015	13.02.2015	09.02.2015	09.02.2015	8.2.2015
Stack attached to	Kiln ESP	COOLER ESP	RAW MILL ESP	CEMENT MILL-1 Bag filter	CEMENT MILL-2 Bag filter	COAL MILL 1&5/VCM Bag filter
Particulate Matter(Mg/Nm3 Isokinetic samples)	89.7	89.6	108.8	84.7	75.7	53.7