

## M/S HEIDELBERGCEMENT INDIA LTD – AMMASANDRA

### Plant -(Grinding Unit )

#### Ambient Air Quality Report for the Month of Aug- 2020

Sl. No	Station/Location		PM10	PM2.5	SO <sub>2</sub>	NO <sub>x</sub>	CO
			µg/m <sup>3</sup>	µg/m <sup>3</sup>	µg/m <sup>3</sup>	µg/m <sup>3</sup>	mg/m <sup>3</sup>
1	Near Time Office	Month Ave	33.6	30.2	8.2	10.9	0.9
2	Near Railway Track	Month Ave	44.3	33.7	14.5	19.2	2.1
3	Near Weigh Bridge	Month Ave	45.6	36.4	14.6	16.7	1.7
4	Near C. C .R	Month Ave	36.8	26.4	11.2	14.4	1.1

#### Stack Monitoring Test Report for the Month of Aug-2020

LOCATION	S-1	S-2
Date of monitoring	**	24.08.2020
Stack attached to	Bag House CEMENT MILL-03	Bag House CEMENT MILL-04
Particulate Matter(Mg/Nm <sup>3</sup> ) -Isokinetic samples	**	18.9

Note: - \*\* Plant was Stopped under not Schedule to Run Hence stack monitoring could not conducted

#### Fugitive emission Monitoring Test Report for the Month of Aug-2020

Sl.No	Location	Date	Particulate Matter (µg/m <sup>3</sup> )
1	Near Packing Plant	08.08.2020	270
2	Slag yard	08.08.2020	330
3	Clinker Yard	08.08.2020	425